





1. Furnish and install one sign depicting National Handicapped Symbol (wheelchair) at each toilet room, equipped with facilities for the handicapped. Size shall be 6" by 6" with 3/8" inch radius corners.
  2. Material: 1/8" thick matte acrylic plastic with all edges eased.
  3. Graphic Process: Raised letters and Braille shall be formed as an integral part of the sign face or surface applied to the sign face.
  4. Colors: Letters and background colors as selected by Architect from manufacturer's standard colors.
  5. Letters: Letters and numbers shall have width to height ratio between 3:5 and 1:1 and a stroke width to height ratio between 1:5 and 1:10. Letters and numbers shall be raised 1/32" upper case sans serif font type with Grade 2 Braille. Raised characters shall be 2" inches high. Pictograms shall be accompanied by the equivalent verbal description placed directly below the pictogram.
  6. Mounting shall be with non-removable oval head screws at locations directed by Architect, 5 foot above finish floor to centerline of sign.
  7. Characters and backgrounds must be eggshell, matte or other non-glaze surface.
- C. Room Name and Number Signs
1. Separate signs for each room name and room number is required. 3" inch high by 10" minimum width for signs, longer where nomenclature demands. 3" inch high by 4 inch minimum for 4 digit numbers and letters, and longer where required. Provide 3/8" radius corners.
  - 2.



- A. Install all signs in strict accordance with manufacturer's instructions and FADA requirements. Room signs to be mounted 60" to center above finish floor on walls adjacent to the latch side of any door opening.

60948 (Imp) 17 sig. 3.1.65193(a.479(n)TC4 -12.96 L5 752.64 E5 752.64 48 678.48 N)e of 696(. )TJ-43.2 -77(696(. )TJ-3.48 678.48 Td (A)4.  
3.2 .1.65193(a.479(n)TW8( r)-081548 678.48 44 -12.96 44 -12.96 A)e of 696(. )TJ-43.2 -77(696(. )TJ-3.48 678.48 Td (A).