

SECTION 16461
DRY TYPE TRANSFORMERS

PART 1 GENERAL

1.1 SECTION INCLUDES:

- A. Two winding transformers.
- B. Two-winding transformers rated for nonlinear loads.
- C. Shielded Transformers.

1.2 REFERENCES

- A. NEMA ST 1 - Specialty Transformers.
- B. NEMA ST 20 - Dry Type Transformers for General Applications.
- C. NFPA 70 - National Electrical Code.

1.3 SUBMITTALS FOR REVIEW

- A. Section 01300 - Submittals: Procedures for submittals.
- B. Product Data: Provide outline and support point dimensions of enclosures and accessories, unit weight, voltage, KVA, and impedance ratings and characteristics, tap configurations, insulation system type, and rated temperature rise.
- C. Test Reports: Indicate loss data, efficiency at 25, 50, 75 and 100 percent rated load, and sound level.
- D. Submit manufacturer's installation instructions. Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, and installation of Product.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Section 01600 - Material and Equipment: Transport, handle, store, and protect products.
- B. Store in a clean, dry space. Maintain factory wrapping or provide an additional heavy canvas or heavy plastic cover to protect units from dirt, water, construction debris, and traffic.
- C. Handle in accordance with manufacturer's written instructions. Life only with lugs provided for that purpose. Handle carefully to avoid damage to transformer internal components, enclosure, and finish.

PART 3 PRODUCTS

2.1 TWO-WINDING TRANSFORMERS

- A. Manufacturers:
 - 1. Square D.
 - 2. Cutler Hammer.
 - 3. General Electric.
 - 4. Substitutions: Under provisions of Section 01600.
- B. Description: NEMA ST 20, factory-assembled, air-cooled, dry type transformers, shown on the drawings.
- C. Primary Voltage: 480 volts, 3 phase.
- D. Secondary Voltage: 208/120 volts, 3 phase.
- E. Insulation system and average winding temperature rise for rated KVA as follows:
 - 1. 1-15 KVA: Class 185 with 115°C rise.
 - 2. 16-500 KVA: Class 150 with 80°C rise.
- F. Case temperature: Do not exceed 35°C rise above ambient at warmest point at full load.
- G. Winding Taps:
 - 1. Transformers less than 15 KVA: Two-5% below rated voltage, full capacity taps on primary winding.
 - 2. Transformers 15 KVA and Larger: NEMA ST 20.

3. Larger than 75 KVA: Suitable for floor or trapeze mounting.
- M. Coil Conductor: Continuous windings with terminations brazed or welded. Individually insulate secondary conductors and arrange to minimize hysteresis and eddy current losses at harmonic frequencies. Size secondary neutral conductor at twice the secondary phase conductor ampacity.
 - N. Electrostatic Shield: Copper, between primary and secondary windings.
 - O. Enclosure: NEMA ST 20, Type 1 or Type 3R, ventilated or non-ventilated. Provide lifting eyes or brackets.
 - P. Isolate core and coil from enclosure using vibration-absorbing mounts.
 - Q. Nameplate: Include transformer connection data and overload capacity bas

3.1 INSTALLATION

- A. Set transformer plumb and level.
- B. Use flexible conduit, under the provisions of Section 16111, 2' minimum length, for connections to transformer case. Make conduit connections to side panel of enclosure.
- C. Mount wall-mounted transformers using integral flanges or accessory brackets furnished by the manufacturer.
- D. Mount floor-mounted transformers on vibration isolating pads suitable for isolating the transformer noise from the building structure.
- E. Mount trapeze-mounted transformers on floor-mounted vibration isolating pads suitable for isolating the transformer noise from the building structure.