

SECTION 09215  
VENEER PLASTER

## PART 1 GENERAL

## 1.1 RELATED DOCUMENTS

- A. The provisions of the General Conditions, Supplementary Conditions, and the Sections included under Division 1, General Requirements, are included as a part of this Section as though bound herein.

## 1.2 SECTION INCLUDES:

- A. Gypsum backing board
- B. Veneer plaster over sheet gypsum, masonry, and concrete surface.

## 1.3 REFERENCES

- A. ASTM C442/C442M - Standard Specification for Gypsum Backing Board, Gypsum Core Board, and Gypsum Shaft-liner Board
- B. ASTM C587 – Standard Specification for Gypsum Veneer Plaster
- C. ASTM C588/C588M – Standard Specification for Gypsum Base for Veneer Plasters.
- D. ASTM C631 – Standard Specification for Bonding Compounds for Interior Gypsum Plastering
- E. ASTM C665 – Standard Specification for Mineral Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing
- F. ASTM C843 – Standard Specification for the Application of Gypsum Veneer Plaster
- G. ASTM C844 – Standard Specification for the Application of Gypsum Base to Receive Gypsum Veneer Plaster
- H. ASTM C1047 – Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base
- I. ASTM E90 – Standard Test Method for Laboratory Measurement of Sound Transmission Loss of Building Partitions
- J. ASTM E119 – Standard Methods for Fire Tests of Building Construction and Materials
- K. GA 150 - Application of Gypsum Base for Gypsum Veneer Plasters and Application of Gypsum Veneer Plaster
- L. GA 216 - Recommended Specifications for the Application and Finishing of Gypsum Board.
- M. GA-600 - Fire Resistance Design Manual.
- N. Warnock-Hersey - Certification Listings.
- O. UL (Underwriters Laboratories, Inc.) - Fire Hazard Classifications.
- P. Florida Building Code.

## 1.4 SYSTEM DESCRIPTION

- A. Acoustic Attenuation for Identified Interior Partitions: 54 STC in accordance with ASTM E90.

## 1.5 SUBMITTALS

- A. Section 01300 - Submittals: Procedures for submittals
- B. Product Data: Provide data on veneer plaster products.
- C. Samples: Submit sample panels, 12" x 12" in size illustrating veneer finish and texture.





- A. Maximum Variation From Specified Thickness: Plus or minus 1/64".

### 3.6 PROTECTION OF FINISHED WORK

- A. Protect finished work.
- B. Do not permit traffic near unprotected finished surfaces.

END OF SECTION